



EFFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.effectis.com

DECLARATION OF TEST RESULTS

No: EEA – 2200 – 0016

The fire resistance tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory on 15.06.2022 in accordance with the test standard:

EN 1634-1:2014+A1:2018

"AK-02 & AK-03"
SINGLE LEAF TIMBER DOORS

FIRE RESISTANCE CLASSIFICATION	
Direction: Opening away from the fire.	E45, EI₂45, EI₁45
Direction: Opening into the fire.	E45, EI₂45, EI₁45

Placed on the market by: **METE DEKORASYON SAN. VE TİC. LTD. ŞTİ.**
Şafak Mah. Akdeniz Sanayi Sit. 5018 Sok. No:9,
Kepez, Antalya/TURKEY

Manufactured by: **METE DEKORASYON SAN. VE TİC. LTD. ŞTİ.**
Şafak Mah. Akdeniz Sanayi Sit. 5018 Sok. No:9,
Kepez, Antalya/TURKEY

e-signed
Ali BAYRAKTAR
Laboratory Manager
15.06.2022

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the report No: EEA-22-050.

